



**General Requirements on Permit-To-Operate (PTO) for Generators
(as of January 15, 2016)**

If a Generator is installed in business establishment, what PTO is required?

There are two (2) PTO's required for Generators, namely:

Type of PTO	Grantor	Concern of the permit
Air Pollution Source Installation (APSI)	DENR Environmental Management Bureau (EMB)	Air pollution.
Internal Combustion Engine (ICE) Installation	DOLE or Local Government Unit (LGU in area of jurisdiction)	Safe installation.

Do I need the above PTO's for my standby generator at home?

No. Generator for residential use does not need to apply for PTO. Unless, your homeowners association would require or if there are local ordinances in your area that would require you to obtain.

What are the requirements in applying for PTO?

For APSI PTO:

1. Application Form from the EMB (www.emb.gov.ph).
2. Pollution Control Officer (PCO) of the establishment using the generator.
3. Certificate of Accreditation of PCO issued by the EMB Regional Office.
3. Installation drawings.
4. Copies of Environmental Compliance Certificate (ECC) or Certificate of Non-Coverage (CNC) of the establishment using the generator.
5. Emission Test from DENR Accredited Stack Testing Firms (Note: Brand new generators 300 kW and below are exempted from emission test as per DENR-EMB Memorandum Circular No. 2007-003).
6. Copy of SEC and DTI Registration of the establishment using the generator.
7. See application form for other requirements.

For ICE PTO:

1. Application Form from the Bureau of Working Conditions (www.bwc.dole.gov.ph) or LGU.
2. Mechanical Plans signed and sealed by Professional Mechanical Engineer (PME).
3. Taxpayer Identification Number (TIN) of the establishment using the generator.
4. See application form for other requirements.